

# Addendum

No. TWO Date: 3.7.19

**Project:**

Cafeteria-Kitchen Expansion for  
West End Elementary School for the  
Etowah County Board of Education  
Gadsden, Alabama

MCKEE PROJECT NO. 16-231

**A2.1 GENERAL MODIFICATIONS:**

The following changes and/or substitutions to the plans and specifications are hereby made a part of same and are incorporated in full force as part of the contract.

Bidders shall acknowledge receipt of this Addendum in writing on his Proposal Form.

**A2.2 SPECIFICATION MODIFICATIONS:**

- A. The following manufactures are hereby approved subject to the plans and specifications:  
  
Section **07500, Membrane Roofing** – Carlisle Syntec
- B. See the following responses to RFI questions received from Contractor's.

**Question:**

Per the plumbing drawings a trench will have to be installed thru the pot wash and kitchen serving area and new flooring will have to be put back but it does not reference this at all on the architectural drawings.

**Answer:** Patch areas with flooring to match existing.

**A2.3 DRAWING MODIFICATIONS: NONE**

**END OF ADDENDUM TWO**