

Addendum

No. Three Date: 1.10.20

Project:

**ADDITION AND RENOVATIONS TO
HIGHLAND HEALTH SYSTEMS FACILITY
ANNISTON, ALABAMA**

MCKEE PROJECT NO. 18.234

The following changes and/or substitutions to the plans and specifications are hereby made a part of same and are incorporated in full force as part of the contract.

Bidders shall acknowledge receipt of this Addendum in writing on his Proposal Form.

A3.1 GENERAL MODIFICATIONS:

NA

A3.2 SPECIFICATION MODIFICATIONS:

NA

A3.3 DRAWING MODIFICATIONS:

NA

A3.4 CLARIFICATIONS & RESPONSES:

1. Office Area 120A shall get new LVT and rubber base. Paint existing walls and refinish doors.
2. Detail C/A5.1 change 4" CMU to 8" CMU as detailed on 7/S2.1 for a total width of 1'-4".
3. There is no sheet A8.2 elevations are on A7.1.

END OF ADDENDUM