

Addendum

No. SEVEN Date: 7.13.20

Project:

**New Educational Facility for the
West Morgan High School for the
Morgan County Board of Education
Decatur, Alabama**

**MCKEE PROJECT NO. 2020.123
ALABAMA DIVISION OF CONSTRUCTION MANAGEMENT NO. 2020086**

The following changes and/or substitutions to the plans and specifications are hereby made a part of same and are incorporated in full force as part of the contract.

Bidders shall acknowledge receipt of this Addendum in writing on his Proposal Form.

A7.1 GENERAL MODIFICATIONS:

A. NONE

A7.2 SPECIFICATION MODIFICATIONS:

A. Refer to Section **15920, Heating, Ventilating and Air Conditioning Building Automation System (BAS)**. **ADD** the attached revision from Zgouvas, Eiring & Associates Consulting Engineers, Inc. dated 7.13.20, herein.

A7.3 DRAWING MODIFICATIONS:


A. NONE

A7.4 CLARIFICATIONS

A. NONE

END OF ADDENDUM

Refer to Specification section 15920, paragraph 1.2: Add the following control system manufacturers in addition to Trane: Johnson Controls, Siemens. Note that the existing system is manufactured by Trane. It is the responsibility of the Controls subcontractor to interface with the existing Trane front end in a seamless manner so that all points at the new school are visible/adjustable via the existing BAS software.



7-13-20