

Addendum No. 5

Date: 08.28.2019

Project:

**RENOVATIONS OF ALBERT COURT APARTMENTS
FOR
THE ALBERTVILLE HOUSING AUTHORITY
ALBERTVILLE, ALABAMA**

MCKEE PROJECT NO. 19-166

The following modifications/ changes and/or substitutions to the plans and specifications are hereby made a part of same and are incorporated in full force as part of the contract documents.

Bidders shall acknowledge receipt of this Addendum in writing on their Proposal Form.

A1.1 GENERAL MODIFICATIONS or CLARIFICATIONS:

- A. The Housing Authority has Sales Tax Exempt Status; therefore, all Bid amounts are **NOT** to include Sales Taxes.
- B. Refer to Electrical Drawings and Specifications and note the following change.
 - SER (Copper) Service Entrance Cable of equal ampacity will be allowed to be used from the utility to the unit panel where allowed by NEC and local jurisdiction having authority.
 - Service Entrance Cable must be copper.
 - All branch conductors from the unit panels must be copper.
 - No aluminum wiring will be accepted

A1.2 SPECIFICATION MODIFICATIONS:

- None

A1.3 DRAWING MODIFICATIONS:

- A. Refer to Mechanical Drawings and Specifications and note the following change.
 - The Contractor has the option to install round ducts in lieu of the square ducts. Note all round duct substitutions must provide an equal CFM compared to the square duct(s) it is replacing. This must be shown in shop drawing format prior to installation.
- B. Refer to Floor Plan Drawings on A1.1 - 2 Bedroom/ 3 Bedroom Unit combination. Note that at the rear entrance, only one door is shown on the floor plan, However, there is both an existing exterior entry door and an existing storm door present.

Provide new hardware for each as specified and refer to “scope of work” note 13 on G1.1.

END OF ADDENDUM