

# Addendum

No. FIVE Date: 4.5.19

## Project:

A PE Facility for  
Verbena High School for the  
Chilton County Board of Education  
Clanton, Alabama

McKee Project No. 19-120

## A5.1 GENERAL MODIFICATIONS:

The following changes and/or substitutions to the plans and specifications are hereby made a part of same and are incorporated in full force as part of the contract.

Bidders shall acknowledge receipt of this Addendum in writing on his Proposal Form.

## A5.2 SPECIFICATION MODIFICATIONS:

- A. See the following responses to RFI questions received from Contractor's

**Question:**

Door Type A is listed as HG for the restrooms. Is that correct?

**Answer:** Doors 102, 103, 104 to be Hollow Metal Type "B" and Frame Type "A".

- B. The following manufactures are hereby approved subject to the plans and specifications:

Section 13120, **Pre-Engineered Metal Buildings** - ACI Building Systems, Inc |  
662.563.4574

## A5.3 DRAWING MODIFICATIONS: NONE

**END OF ADDENDUM FIVE**